Ref. Certificate No.
NL-36610

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product Produit	LED driver
Name and address of the Applicant Nom et adresse du demandeur	Philips (China) Investment Co., Ltd. #9, Lane 888 Tianlin Road, Shanghai Business Park, 200233 Shanghai China
Name and address of the manufacturer Nom et adresse du fabricant	Philips (China) Investment Co., Ltd. #9, Lane 888 Tianlin Road, Shanghai Business Park, 200233 Shanghai China
Name and address of the factory Nom et adresse de l'usine	Philips Lighting Poland S.A. ul. Przemyslowa 29 64-290 PILA Poland
Rating and principal characteristics Valeurs nominales et caractéristiques principales	Xi FP 150W 0.2-0.7A SNLDAE 230V S240 sXt Pin:162W; Uin: 220-240 V~; Iin: 0,8-0,67 A~; Uin: 186-250 V dc; Iin: 0,6 A max dc; Freq: 50/60 Hz; DC; PF: 0,95; Pout:150W; Uout: 90-283 V;Iout: 200-700 mA; ta: -40…+55 °C;tc(max): 90 °C Xi FP 150W 0.3-1.0A SNLDAE 230V S240 sXt Pin:162W; Uin: 220-240 V~; Iin: 0,76-0,67 A~; Uin: 186-250 V dc; Iin: 0,6 A max dc; Freq: 50/60 Hz; DC; PF: 0,95; Pout:150W; Uout: 70-214 V; Iout: 300-1050 mA; ta: -40…+55 °C;tc(max): 90 °C Xi FP 75W 0.2-0.7A SNLDAE 230V S240 sXt Pin:82W; Uin: 220-240 V~; Iin: 0,4-0,34 A~; Uin: 186-250 V dc; Iin: 0,3 A max dc; Freq: 50/60 Hz; DC; PF: 0,95; Pout:75W; Uout: 50-150V; Iout: 200-700 mA; ta: -40…+55 °C; tc(max): 85 °C Xi FP 75W 0.3-1.0A SNLDAE 230V S240 sXt Pin:82W; Uin: 220-240 V~; Iin: 0,4-0,34 A~; Uin: 186-250 V dc; Iin: 0,3A max dc; Freq: 50/60 Hz; DC; PF: 0,95; Pout:75W; Uout: 35-108 V; Iout: 300-1050 mA; ta: -40…+55 °C; tc(max): 85 °C
Trademark (if any) Marque de fabrique (si elle existe)	PHILIPS
Type of manufacturer's Testing Laboratories used Type de programme de laboratoire d'essais constructeur	
Model / Type Ref. Réf. de type	Xi FP 150W 0.2-0.7A SNLDAE 230V S240 sXt Xi FP 150W 0.3-1.0A SNLDAE 230V S240 sXt Xi FP 75W 0.2-0.7A SNLDAE 230V S240 sXt Xi FP 75W 0.3-1.0A SNLDAE 230V S240 sXt

This CB Test Certificate is issued by the National Certification Body:

Ce Certificat d'essai OC est établi par l'Organisme National de Certification

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

DEKRA

Date: 2015-06-26

Signature: T. Drost

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

Additional information (if necessary may also be reported on page 2) Les informations complémentaires (si nécessaire, peuvent être indiquées sur la 2ème page)	
A sample of product was tested and found to be in conformity with IEC Un échantillon de ce produit a été essayé et été considéré conforme à la CEI	61347-1(ed.2);am1;am2 61347-2-13(ed.2)
As shown in the test report Ref. No. which forms part of this certificate Comme indiqué dans le rapport d'essais numéro de référence qui constitue partie de ce certificat	2183840.50

This CB Test Certificate is issued by the National Certification Body:

Ce Certificat d'essai OC est établi par l'Organisme National de Certification

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

DEKRA

Date: 2015-06-26

Signature: T. Drost