



1 x TLED8.5W 5000K 160D 9290011182

1 x 1100 lm

Polar intensity diagram

Light output ratio 1.00
 Service upward 0.16
 Service downward 0.84

CIE flux code 38 66 87 84 100

Quantity estimation diagram**Utilisation factor table**

Room Index k	Reflectances (%) for ceiling, walls and working plane (CIE)											
	0.80	0.80	0.70	0.70	0.70	0.70	0.50	0.50	0.30	0.30	0.00	0.00
0.60	0.42	0.40	0.40	0.40	0.39	0.31	0.30	0.25	0.28	0.24	0.21	0.21
0.80	0.52	0.48	0.50	0.48	0.47	0.39	0.37	0.32	0.35	0.30	0.27	0.27
1.00	0.60	0.55	0.57	0.55	0.54	0.46	0.43	0.38	0.41	0.36	0.32	0.32
1.25	0.68	0.62	0.65	0.62	0.60	0.52	0.50	0.44	0.47	0.42	0.38	0.38
1.50	0.74	0.67	0.71	0.68	0.65	0.58	0.54	0.49	0.51	0.47	0.42	0.42
2.00	0.83	0.75	0.80	0.76	0.72	0.66	0.62	0.57	0.59	0.55	0.49	0.49
2.50	0.90	0.80	0.86	0.81	0.77	0.71	0.67	0.63	0.64	0.60	0.54	0.54
3.00	0.95	0.83	0.90	0.85	0.81	0.75	0.71	0.67	0.67	0.64	0.58	0.58
4.00	1.01	0.88	0.96	0.90	0.85	0.81	0.76	0.73	0.72	0.69	0.63	0.63
5.00	1.06	0.91	1.00	0.94	0.88	0.84	0.79	0.77	0.75	0.73	0.66	0.66

Ceiling mounted

Luminance Table

Plane, Cone	0.0	15.0	30.0	45.0	60.0	75.0	90.0
45.0	4321	4238	4299	4517	4918	5594	6703
50.0	4133	4030	4075	4282	4662	5339	6524
55.0	3961	3834	3858	4048	4393	5052	6297
60.0	3803	3654	3660	3834	4129	4747	6026
65.0	3658	3488	3475	3633	3859	4402	5666
70.0	3430	3271	3272	3452	3592	4025	5213
75.0	3439	3227	3178	3310	3343	3618	4599
80.0	3358	3133	3079	3215	2779	2137	101
85.0	3286	3036	2963	3086	2885	2720	2289
90.0	3224	2948	2857	2970	2766	2589	791

(cd/m²)

SL13940

2014-04-29