



1 x TLED10.5W 5000K165D 9290011186**1 x 1270 lm****Polar intensity diagram**

Light output ratio 1.00
 Service upward 0.15
 Service downward 0.85


CIE flux code 38 66 87 85 100

UGRcen (4Hx8H, 0.25H) 23

Quantity estimation diagram**Utilisation factor table**

Room Index k	Reflectances (%) for ceiling, walls and working plane (CIE)											
	0.80 0.80				0.70 0.70				0.50 0.50			
	0.80	0.50	0.30	0.10	0.70	0.50	0.30	0.10	0.50	0.30	0.10	0.00
0.60	0.42	0.40	0.30	0.10	0.41	0.40	0.39	0.31	0.30	0.25	0.28	0.21
0.80	0.52	0.49	0.50	0.48	0.47	0.39	0.37	0.32	0.35	0.31	0.27	0.27
1.00	0.60	0.55	0.57	0.56	0.54	0.46	0.44	0.38	0.41	0.37	0.33	0.33
1.25	0.68	0.62	0.65	0.62	0.60	0.53	0.50	0.45	0.47	0.43	0.38	0.38
1.50	0.74	0.67	0.71	0.68	0.65	0.58	0.55	0.50	0.52	0.47	0.43	0.43
2.00	0.84	0.75	0.80	0.76	0.72	0.66	0.62	0.58	0.59	0.55	0.50	0.50
2.50	0.90	0.80	0.86	0.81	0.77	0.71	0.68	0.63	0.64	0.60	0.55	0.55
3.00	0.95	0.83	0.91	0.85	0.81	0.76	0.72	0.68	0.68	0.64	0.59	0.59
4.00	1.02	0.88	0.97	0.91	0.85	0.81	0.77	0.73	0.73	0.70	0.64	0.64
5.00	1.06	0.91	1.01	0.94	0.88	0.84	0.80	0.77	0.76	0.73	0.67	0.67

Ceiling mounted

UGR diagram**Luminance Table**

Plane Cone	0.0	15.0	30.0	45.0	60.0	75.0	90.0
45.0	5080	5048	5121	5306	5675	6454	7891
50.0	4858	4813	4867	5023	5345	6120	7679
55.0	4655	4596	4626	4746	5009	5754	7410
60.0	4470	4399	4405	4485	4667	5349	7073
65.0	4301	4216	4198	4238	4320	4898	6624
70.0	4147	4050	4008	4005	3977	4403	6018
75.0	4010	3899	3835	3793	3634	3847	5175
80.0	3889	3768	3683	3603	3317	3266	3982
85.0	3786	3655	3555	3447	3050	2718	2189
90.0	3706	3565	3455	3327	2862	2454	536

(cd/m²)

SL10662-TL

2014-04-29