





Project:	
Location:	
Cat.No:	
Туре:	
Lamps:	Qty:
Notes:	

Example: 1TG32L840-4-FS-02F-UNV-DIM

The Philips Day-Brite / Philips CFI T-Grid LED troffer is an energy efficient low profile luminaire offering excellent performance for general lighting applications such as offices, schools, healthcare, or retail. Featuring a frosted prismatic lens to enhance visual comfort, the T-Grid LED Troffer utilizes highly reliable and efficient Philips LED platform boards and dimmable driver, enabling market leading efficiency in its category.

Ordering guide

Width	Family	Ceiling Type	Lume Packa		Color	Temp.	Leng	gth	Do	or Fr	ame	Lens		Volt	age	Drive	r	Options	
1	Т	G				_	4	_			_	02F	_		_				
1 1'	T T-Grid LED troffer	G Grid	32L 42L 50L	2200 nominal delivered lumens 3200 nominal delivered lumens 4200 nominal delivered lumens 5000 nominal delivered lumens	830 835 840 850	80 CRI, 3000K 80 CRI, 3500K 80 CRI, 4000K 80 CRI, 5000K	4	4'		Re	it Steel gressed iminum	02F	Pattern 12, .100" nominal diffuse 50%	347	Universa Voltage 120-277 347V		0-10V dimming Step dimming to 40% input power	F1 F2 F1/D F2/5W EMLED¹ 1W 2W 3W	3/8" flex, 3 wire, 18 gauge 6' 3/8" flex, 4 wire, 18 gauge 6' 3/8" twin flex, 3 wire, 18 gauge 6', for dimmable luminaires 3/8" single flex, 5 wire, 18 gauge 6', for dimmable luminaires Integral emergency battery pack 1-way gasket between lens & door frame (not avail. for RA door frame) 1-way & gasket between door frame & housing 2-way & gasket betweem housing & ceiling (field installed) Fusing, fast blow Chicago Plenum rated

Footnotes

1 1100 nominal lumens delivered in DC mode

Accessories (order separately)

- FMA14 1'x4' "F" mounting frame for NEMA "F" mounting
- GCP Grid clip pack (1'x4')





1TG T-Grid LED troffer 1x4

2200, 3200, 4200 or 5000 lumens

Application

- High efficacy long life solid state lighting platform.
- General lighting distribution is excellent for ambient lighting.
- High CRI source provides excellent color rendering.
- LEDs are an excellent source for use with controls since frequent switching does not affect the life of a light source.

Construction/finish

- Quality recessed troffer for the following "NEMA" ceiling types: NEMA "G"-Grid, NEMA "NFSG"-Narrow Faced Slot Grid, NEMA "GR"-Grid Regressed, NEMA "NFG"-Narrow Faced Grid.
- Field assembled and installed "F" mounting Frame adapts fixture for use in NEMA "F" ceilings requiring flanges.
- · Housing is constructed of pre-painted steel.
- Troffer body die-formed CR steel with reinforcing ribs for rigidity.
- 7/8 K.O.'s provided in each end cap and quick wire access plate in housing top with two 7/8 K.O.'s provided.
- · Snap on wireway cover.

- T-bar clips are not integral to the luminaire, and must be ordered separately.
- Low profile body minimizes clearance required
- All units have wire hanger tabs for independent wire suspension.

Electrical


- · Standard 0-10V dimming.
- Driver and LED boards are accessible from below. LED boards are individually replaceable if required.
- Five-year luminaire limited warranty including LED boards and driver. Visit www.philips. com/warranties for complete warranty information.
- High efficiency LEDs have 50,000 hour rated life (defined by testing at 70% lumen maintenance (L70)), based on 25°C ambient operating temperature.
- · UL listed, suitable for damp locations.
- · No exposed internal wiring.
- cETLus listed to UL and CSA standards, suitable for damp location.


- T-Grid LED luminaires are DesignLights Consortium® qualified. Please see the DLC QPL list for exact catalog numbers (http://www. designlights.org/QPL).
- Many luminaire components, such as reflectors, refractors, lenses, sockets, lampholders, and LEDs are made from various types of plastics which can be adversely affected by airborne contaminants. If sulfur based chemicals, petroleum based products, cleaning solutions, or other contaminants are expected in the intended area of use, consult factory for compatibility.

Enclosure

- · Flat steel door frame has mitered corners.
- Hinged and latched (from either side) door frame.
- Mechanically designed interlocks eliminate light leaks.
- White (standard) or black (optional) door frames available.
- Diffuser is clear color stabilized 100% prismatic acrylic.

Dimensions





1TG T-Grid LED troffer 1x4

2200, 3200, 4200 or 5000 lumens

Photometry

1x4 T-Grid LED troffer, 2200 nominal delivered lumens

LER - 106

		Candle	power		Light Distribution					Average Luminance				
Catalog No.	1TG22L840-4-FS-02F-UNV	Angle	End	45	Cross	Degre	es L	umens	% Lumir	naire	Angl	e End	45°	Cross
Test No.	33591	0	1055	1055	1055	0-30		789	34.5		45		2448	2252
S/MH	1.1	5	1045	1049	1051	0-40 0-60		1235 1924	54.1 84.3		55 65		1911 1503	1733 1424
Lamp Type	LED	15 25	998 897	1000 886	996 873	0-90		2283	100.0		75	1709	1385 1425	1356 1397
Lumens	2284	35 45	744 558	715 511	685 470	C45	-:	~ £ 1 14:	liti		0.	1301	1423	1337
Input Watts	21.6	55	372	324	294	Соети	cients	or Uti	lization					
-		65	224	188	178	EFFECTIV	VE FLOOI		/ REFLECTA	NCE 20 P	ER (pfc	0.20)		
Comparativo voa	arly lighting energy cost per 1000	75	131	106	104	рсс		80			70		50	
	based on 3000 hrs. and \$.08 pwr	85	51	37	36	pw RCR	70	50	30	70	50	30	50	30
KWH.	based on 5000 fils. and 5.00 pwi					0	118	118	118	115	115	115	111	111
IXVVII.						1	110	105	101	107	103	98	98	95
The photometric	results were obtained in the					2	101	93	86	97	91	84	88	82
	laboratory which is NVLAP					3	93	82	75	90	81	73	78	71
	e National Institute of Standards					4	84	73	66	82	72	65	69	64
and Technology.						5	79	67	58	77	66	57	64	56
						7	72 68	60 56	52 46	71 67	59 55	52 46	57 53	51 46
	ues based on test performed in					8	64	51	40	61	50	40	48	40
compliance with	LM-/9.					9	59	46	39	58	46	39	45	39
						10	56	44	35	55	42	35	41	35

1x4 T-Grid LED troffer, 3200 nominal delivered lumens

LER - 104

		Candle	power			Light	Distrib	ution		Average Luminance				
Catalog No.	1TG32L840-4-FS-02F-UNV	Angle	End	45	Cross	Degre	ees L	umens	% Lumir	naire	Angle	End	45°	Cross
Test No.	33592	0	1460	1460	1460	0-30		1092	34.5		45	3698	3398	3118
S/MH	1.1	5	1447	1452	1455	0-40 0-60		1709 2664	54.1 84.2		55 65	3040 2483	2650 2090	2399 1970
Lamp Type	LED	15 25	1380 1240	1384 1228	1378 1208	0-90		3161	100.0		75 85	2371 2730	1925 1990	1877 1909
Lumens	3163	35 45	1029 772	992 710	948 651	Cooff	cionto	of 1146	lization		0.5	2/30	1330	1303
Input Watts	30.4	55	515	449	406	Coeiii	cients	טו טנו	lization					
<u> </u>		65	310	261	246	EFFECT	IVE FLOOF	R CAVITY	REFLECTA	NCE 20 P	ER (pfc=	0.20)		
Comparative year	ly lighting energy cost per 1000	75	181	147	143	pcc		80			70		50	
	ased on 3000 hrs. and \$.08 pwr	85	70	51	49	pw RCR	70	50	30	70	50	30	50	30
KWH.	13cd on 3000 ms. and 3.00 pwi					nck 0	118	118	118	115	115	115	111	111
						1	110	105	101	107	103	98	98	95
The photometric	results were obtained in the					2	101	93	86	97	91	84	88	82
	laboratory which is NVLAP					3	93	82	75	90	81	73	78	71
	National Institute of Standards					4	84	73	66	82	72	65	69	64
and Technology.						5	79	67	58	77	66	57	64	56
						6	72 68	60 56	52 46	71 67	59 55	52 46	57 53	51 46
	es based on test performed in					2	64	51	40	61	50	40	48	40
compliance with I	_IVI-/9.					9	59	46	39	57	46	39	45	39
						10	56	44	35	55	42	35	41	34

1TG T-Grid LED troffer 1x4

2200, 3200, 4200 or 5000 lumens

Photometry

1x4 T-Grid LED troffer, 4200 nominal delivered lumens

LER - 101

		Candlepower					Light Distribution					Average Luminance				
Catalog No.	1TG42L840-4-FS-02F-UNV	Angle	End	45	Cross	Degr	ees l	Lumens	% Lumii	naire	Angle	e End	45°	Cross		
Test No.	33599	0	2030	2030	2030	0-30		1518	34.5		45	5151	4719	4352		
S/MH	1.1	5	2011	2020	2023	0-40 0-60		2378 3708	54.0 84.2		55 65	4233 3465	3691 2904	3348 2754		
Lamp Type	LED	15 25	1919 1727	1926 1709	1918 1682	0-90		4404	100.		75 85	3304	2676	2624		
Lumens	4404	35 45	1432 1076	1379 985	1321 909	Coeff	icients	of Uti	lization		65	3806	2750	2680		
Input Watts	43.6	55 65	717 432	625 362	567 344	EFFECTIVE FLOOR CAVITY REFLECTANCE 20 PER (pfc=0.20)										
Commonstive	ville lighting analysis sast nov 1000	75	253	205	201	рсс		80			70		5			
	arly lighting energy cost per 1000 based on 3000 hrs. and \$.08 pwr	85	98	71	69	pw RCR	70	50	30	70	50	30	50	30		
KWH.	based off 5000 fils. and \$.06 pwi					0	118	118	115	115	115	111	111			
KWII.						1	110	105	101	107	103	98	98	95		
The photometric	results were obtained in the					2	101	93	86	97	91	84	88	82		
	laboratory which is NVLAP					3	93	82	75	90	81	73	78	71		
	e National Institute of Standards					4	84	73	66	82	72	65	69	64		
and Technology.						5	79 72	67 60	58 52	77 70	66 59	57 52	64 57	56 51		
51						7	68	56	46	67	55	46	53	46		
	ues based on test performed in					8	64	51	42	61	50	42	48	41		
compliance with	LIVI-79.					9	59	46	39	57	46	39	45	39		
						10	56	44	35	55	42	35	41	34		

1x4 T-Grid LED troffer, 5000 nominal delivered lumens

LER - 98

		Candlepower					Light Distribution					Average Luminance				
Catalog No.	1TG50L840-4-FS-02F-UNV	Angle	End	45	Cross	Degre	ees I	Lumens	% Lumi	naire	Angle	e End	45°	Cross		
Test No.	33596	0	2337	2337	2337	0-30		1749	34.4		45	5929	5457	5009		
S/MH	1.1	5	2315	2325	2329	0-40 0-60		2740 4275	54.0 84.2		55 65		4265 3368	3853 3171		
Lamp Type	LED	15 25 35	2209 1986 1650	2217 1968 1590	2208 1935 1522	0-90		5075	100.		75 85	3813	3099 3210	3021 3089		
Lumens Input Watts	5078 51.9	45 55	1238 827	1140 723	1046 653	Coefficients of Utilization EFFECTIVE FLOOR CAVITY REFLECTANCE 20 PER (pfc=0.20)										
		65 75	498 291	420 237	396 231	1 1	IVE FLOO	R CAVIII	Y REFLECT	INCE 20 P		0.20)	5	0		
Comparative year	arly lighting energy cost per 1000	85	113	83	80	pcc	70	50	30	70	70 50	30	50	30		
	based on 3000 hrs. and \$.08 pwr		5	03	00	RCR										
KWH.						0	118	118	118	115	115	115	111	111		
						1	110	105	101	107	103	98	98	95		
	results were obtained in the					2	101 93	93 82	86 75	97 90	91 81	73	88 78	82 71		
	e laboratory which is NVLAP e National Institute of Standards					4	84	73	66	82	72	65	69	64		
and Technology.						5	79	67	58	77	66	57	64	56		
and recimology.						6	72	60	52	70	59	52	57	51		
Photometric valu	ues based on test performed in					7	68	56	46	67	55	46	53	46		
compliance with						8	64	51	42	61	50	42	48	41		
						9	59 56	46 44	39 35	57 55	46 42	39 35	45 41	38 34		
						IU	סכ	44	20)))	42	ככ	41	34		

© 2015 Koninklijke Philips N.V. All rights reserved. Philips reserves the right to make changes in specifications and/or to discontinue any product at any time without notice or obligation and will not be liable for any consequences resulting from the use of this publication. philips.com/luminaires



Philips Lighting, North America Corporation 200 Franklin Square Drive, Somerset, NJ 08873 Tel. 855-486-2216

Philips Lighting Canada Ltd. 281 Hillmount Rd, Markham, ON, Canada L6C 2S3 Tel. 800-668-9008