

Emergency Driver for Philips Evokit Class 2 Output



A Division Of Philips Electronics North America Corporation

Product Summary

UL RECOGNIZED



(Indoor and Damp)
Output Class 2 Compliant
*503441 is field installable when used with the Philips
EvoKit G2 LED Retrofit luminaire.

Illumination Time

90 Minutes

Full Warranty

5 Years (NOT pro-rata)

Universal Input Voltage

120-277 VAC, 50/60 Hz

AC Input Current

60 mA Maximum

AC Input Power Rating

4.0 W Maximum

Output Current and Voltage

Selectable (See Table 1)

Without Selector: minimum 200 mA, 35-50 VDC,
minimum 300 mA over optimized range (30-34 VDC)

With Selector: minimum 400 mA, 10-29 VDC

Output Power

10.0 W (Maximum)

Test Switch/Charging Indicator Light

Illuminated Test Switch

Battery

High-Temperature,
Maintenance-Free
Nickel-Cadmium Battery
7- to 10-Year Life Expectancy

Battery Charging Current

180 mA

Recharge Time

24 Hours

Temperature Rating (Ambient)


0°C to +55°C
(32°F to 131°F)

Dimensions (503441)

14.5" x 2.25" x 1.18"
(369 mm x 58 mm x 30 mm)
Mounting Center 14.0" (356 mm)

Weight

2.25 lbs. (1.0 kg) - polycarbonate



Application

The 503441 universal input (120-277 V) emergency LED driver works in conjunction with an AC LED driver that has an output current not to exceed 3.0 A. The emergency driver consists of a high-temperature nickel-cadmium battery, charger and electronic circuitry in one case. The 503441 can deliver up to 10 watts to an LED load (measured at nominal battery voltage) for 90 minutes. If used in an emergency-only fixture, no AC driver is necessary. The 503441 is suitable for indoor and damp locations. For more information about specific LED and AC driver compatibility, please call the factory.

Operation

When AC power fails, the 503441 immediately switches to the emergency mode, operating the LEDs at a reduced lumen output for a minimum of 90 minutes. When AC power is restored, the emergency driver automatically returns to the charging mode. A patented circuit delays AC LED driver operation for up to 5 seconds to prevent over current of LED's that would occur if both drivers supply the load at the same time.

Installation

The 503441 does not affect normal fixture operation and may be used with either a switched or unswitched fixture. If a switched fixture is used, an unswitched hot lead must be connected to the emergency driver. The emergency driver must be fed from the same branch circuit as the AC driver. Per UL requirements, the polycarbonate 503441 must be enclosed if remote mounted outside of the fixture. Installation is not recommended with fixtures where the ambient temperature may fall below 0° C. The product is suitable for installation in sealed and gasketed fixtures. For LED loads rated less than 30V, connect the load select per Table 1 for proper operation and optimum performance.

*503441 is field installable when used with the Philips EvoKit G2 or G3 LED Retrofit kits.

UL and Code Compliance

The 503441 has been tested by Underwriters Laboratories in accordance with the standards set forth in UL 924, "Emergency Lighting and Power Equipment," and is UL Recognized for factory installation only. Emergency illumination time exceeds the National Electrical Code (NEC), Life Safety Code (NFPA-LSC) and UL 90-minute requirements.

Specifiers Reference

Project _____ Type _____ Model No. _____
Comments _____

L2300211

10/14/14 © Philips Lighting
10275 W. Higgins Rd., IL USA .
www.philips.com/advance

Emergency Driver for Philips Evokit Gen2 Class 2 Output

Emergency Illumination

The 503441 operates an LED load of up to 10.0 W at nominal battery voltage for a minimum of 90 minutes.

Specification

Emergency lighting shall be provided by using a LED fixture equipped with a Philips 503441 universal input (120-277 V) emergency driver. A patented circuit delays AC LED driver operation for up to 5 seconds to prevent over current of LED's that would occur if both drivers supply the load at the same time. This emergency driver shall consist of a high-temperature, maintenance-free nickel-cadmium battery, charger and electronic circuitry contained in one case. An illuminated test switch (ITS) to monitor charger and battery and installation hardware shall be provided. The emergency driver shall be capable of delivering up to 10 watts to an LED load for a minimum of 90 minutes. The 503441 is suitable for indoor and damp locations. The 503441 shall have a maximum of 4.0 watts of input power and a 24.0 Watt-hour battery capacity and shall comply with emergency standards set forth by the current NEC. The emergency driver shall be UL Recognized for factory installation only and shall be warranted for a full five years from date of purchase.

Warranty

Model 503441 is warranted for five (5) full years from date of purchase. This warranty covers only properly installed Philips emergency LED drivers used under normal conditions. For the warranty period, Philips Lighting will, at its option, repair or replace without charge a defective emergency LED driver, provided it is returned to the factory transportation prepaid and our inspection determines it to be defective under terms of the warranty. Repair or replacement, as stated above, shall constitute the purchaser's exclusive warranty, which does not extend to transportation, installation, labor or any other charges; nor does it apply to any equipment of another manufacturer used in conjunction with the emergency driver.

IMPORTANT: LOAD SELECT Jumper wire is not used with Evokit G2 or G3

LOAD SELECT OPTIONS

MAXIMUM LOAD VOLTAGE	LOAD SELECT
10V - 29V	CONNECTED
30V - 50V	NOT CONNECTED




TABLE 2b. Listed Luminaires

Manufacturer	Model Number
Philips	EvoKit LED Retrofit Luminaire

Benefits:

- Enables Evokits to meet Emergency Code requirements
- Emergency mode lumen output of up to 1300 lumens
- Universal input (120-277 VAC)
- 2 wire input reduces wiring errors

Table REMOTE DISTANCES

Wire Gauge (AWG)	Maximum Remote Mounting Distance* (ft)	Maximum Wire Length** (ft)
10	500	1000
12	300	600
14	200	400
16	125	250
18	75	150
20	50	100
22	30	60
24	20	40
26	13	26

* Total wire length can NOT exceed that given in Maximum Wire Length column.

** Distance is round trip wire length.

Distances are for Emergency Driver only. Consult AC Driver specification for remote mounting distances when using AC Driver.

TBD